

Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek Warnock Hersey Mark for Wall Assemblies

CAN / ULC S102 (2010), NFPA 285 (2012), ASTM E84 (2013a), ASTM E119 (2012a), CAN / ULC S134 (2013)

Certificate number: **WHI18 – 26206601**

Organization:

Unience Co., Ltd.
46, Gwahaksaneop 1-Ro
Oksan -Myeon, Heungdeok-Gu
Cheongju-Si, Chungcheongbuk-Do , 28122
South Korea

Product: Unience Co. Ltd. - ALFREX SPEC ID 36858

ALFREX is an Aluminum Composite Panel that has a surfaced finish on the aluminum skin.

RATINGS

| Standard | Rating | Design Number |
|--|---|------------------|
| ASTM E84 (4mm panel exterior side exposed) | Flame Spread Index:0 Smoke Developed Index:0 | NA |
| ASTM E84 (Core Exposed) | Flame Spread Index:20 Smoke Developed Index:55 | NA |
| NFPA 285 | Met Criteria of Standard | UCL/MCMWP 30-01 |
| ASTM E119 | Fire Resistance Rating: 2hr | UCL/MCMWP 120-01 |
| CAN/ULC S102 | Flame Spread Index: 0 Smoke Developed Classification: 5 | NA |
| CAN/ULC S134 | Met Criteria of Standard | UCL/MCMWP 25-01 |

Certification body: Intertek Testing Services NA, Inc.

Initial registration: March 5th, 2018

Date of expiry: March 5th, 2023

Issue status: 1

| | | |
|--|-----------|-----------|
| Charles Meyers Certification Coordination Manager | | 3/05/2018 |
| Name | Signature | Date |

www.intertek.com

Registered address:

Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.